

SOLAPUR TRANSMISSION LIMITED
(100% wholly owned subsidiary of Torrent Power Ltd)
2, Dharam Marg, Chanakyapuri,
New Delhi -110021

NOTICE

(Under Sub-section (2) Section 15 of the Electricity Act, 2003)

1. **Solapur Transmission Limited**, having its Registered Office at **2, Dharam Marg, Chanakyapuri, New Delhi -110021**, which is incorporated under the Companies Act, 2013 has made an application before Central Electricity Regulatory Commission under sub section (1) of Section 15 of the Electricity Act, 2003 for grant of Transmission Licence in respect of the Transmission Lines, Sub-station and other assets, the details of which are given below:

<i>Inter State Transmission System for Evacuation of Power from RE Projects in Solapur (1500 MW) SEZ in Maharashtra</i>					
Sl. No.	Name of Transmission Element	Capacity/km	Annual Transmission Charges (in Rs Crore per annum)	Commissioning Schedule	Remarks
1.	<p>Establishment of 400/220 kV, 4x500 MVA ICTs at Solapur PS along with 2x125 MVAR, 420 kV Bus Reactors</p> <p>Future provisions: Space to accommodate:</p> <ul style="list-style-type: none"> • 400/220 kV, 500 MVA ICT along with associated bays – 6 Nos. • 400 kV line bays along with switchable line reactors: 12 Nos. • 420 kV, 2x125 MVA Bus Reactor with Bays • 15 nos. of 220 kV line bays • Sectionaliser arrangement at 220 kV level (3 Sets) & 400 kV level (1 Set) • 220 kV TBC bay – 3 Nos. • 220 kV BC bay – 3 Nos. 	<p>400/220 kV, 500 MVA ICT – 4 Nos.</p> <p>400 kV ICT bays – 4 Nos.</p> <p>220 kV ICT bays – 4 Nos.</p> <p>400 kV line bays – 2 Nos.</p> <p>220 kV line bays for solar park interconnection – 5 Nos.</p> <p>125 MVA, 420 kV Bus reactor – 2 Nos</p> <p>400 kV Bus reactor bay: 2 Nos.</p> <p>220 kV TBC bay – 1 No.</p> <p>220 kV BC bay – 1 No.</p>	50	24 Months from Effective Date	

2.	Solapur PS -Solapur (PG) 400kV D/c line (Quad ACSR/AAAC/AL59 moose equivalent)	Route length ~ 30 km			
3.	2 nos. of 400kV line bays at Solapur (PG) S/s for termination of Solapur PS- Solapur (PG) 400kV D/c line.	400kV line bays – 2 Nos. [for Solapur (PG) end]			

Note: POWERGRID shall provide space for 2 Nos. of 400kV bays at Solapur (PG) for termination of Solapur PS- Solapur (PG) 400kV D/c line.

2. Complete petition and other documents filed before the Commission are available on the web site <https://www.torrentpower.com> for access by any person. The petition can also be inspected at the office of Torrent Power Limited, having its Office at “600” Samanvay, Tapovan, Ambavadi, Ahmedabad-380015 (Gujarat) with Shri Mihir Thakkar or Office of the Commission in accordance with the procedure specified in by the Commission.
3. Objections or suggestions, if any, be filed before the Secretary, Central Electricity Regulatory Commission (3rd & 4th Floor, Chander Lok Building, 36, Janpath, New Delhi- 110001), with a copy of the objection(s)/suggestion(s) to the petitioner, within 30 days of the publication of the notice in the newspaper.

Place: Ahmedabad
Date: 28.03.2024

Sd/-
For Solapur Transmission Ltd
Mihir Thakkar